Backflow & cross-connections

Owner observations and utility testing reminders

PROPERTY / SITE ADDRESS

PROVINCE: AB / BC ASSET / AREA ID

COMPLETED BY / ROLE

DATE / TIME

FOURPOINT RECOMMENDED OWNER ROUTINE
Recommended owner round: monthly, and after plumbing or water-use changes. Confirm the required certified test interval with your water utility; a monthly visual round does not replace testing.

Tick one: Observed = no concern noted; Follow up = concern / not assessed; N/A = not applicable. Visual only; does not prove operation.

OWNER OBSERVATION / HOUSEKEEPING	Observed	Follow up	N/A
01 Device ID, location and water utility are recorded; the device and its service area remain accessible.	☐	☐	☐
02 Look for leakage, unusual discharge, flooding, freeze exposure or impact damage; report rather than adjust the device.	☐	☐	☐
03 Observe that existing discharge/drain arrangements have not been obstructed or altered; do not fit hoses or plugs.	☐	☐	☐
04 Hose ends are kept out of tanks, sinks, chemical containers and other potentially contaminated water; report risky connections.	☐	☐	☐
05 Record new equipment, irrigation, process uses, temporary connections or plumbing alterations for qualified/utility review.	☐	☐	☐
06 Latest test report and utility-required next test date are recorded; follow up on overdue or failed test reports.	☐	☐	☐
07 Use a tester accepted by the water utility and keep proof of test submission where required.	☐	☐	☐

Utility / device ID: _____ Certified test due: _____

FINDINGS / LOCATION / PHOTO REFERENCE / PERSON NOTIFIED

Follow-up owner: _____ Target date: _____ Next owner round: _____

QUALIFIED WORK / LIMITS: Leave test-cock/valve operation, certification tests, bypasses, repairs, cleaning and device selection to qualified personnel accepted by the utility. Aquatera requires annual testing for ICI customers; confirm the rules for your property.

ACT PROMPTLY: Report suspected impairment to the site fire-safety contact and qualified provider; follow the site impairment plan. Fire or immediate danger: follow the emergency plan and call 911.

Aquatera cross-connection program; AB / BC code sources. See the schedule guide for applicability.